

File Ref: BUR1001

29 July 2015

Brett Oldfield
Combustion Control Ltd
PO Box 13-454
Onehunga
Auckland 1643

Dear Brett

Burner Renewal

I am pleased to advise that your application the renewal the following burner has been approved.

BUR1001 – MAIOR, MINOR, OILFLAM (models as submitted)

A copy of the approval is attached. The renewal will be recorded in the register of approved burners on the website of WorkSafe New Zealand.

Please take note of all the conditions attached to the approval. These conditions may be different from the original approval as changes have been made over time.

Yours sincerely



Dick Burgess
Advisor
Certifications, Approvals and Registrations Team

DECISION

Under Clause 68 of Schedule 8 of the Hazardous Substances (Dangerous Goods and Scheduled Toxic Substances) Transfer Notice 2004, the Authority may approve a burner for the combustion of class 3.1 substances.

| Burners | |
|------------------|--|
| Register Number | BUR1001 |
| Application Type | Renewal |
| Applicant | Combustion Control Ltd |
| Burner type | Ecoflam Bruciatori S.p.A. |
| | MAIOR P10, P15, P25, P35, P45, P60, P80, P120, P150.1, P200.1, P300.1, P400.1, P500.1, P600.1, P800.1, P1000.1, P1200.1, P1500.1, P1800.1 |
| Model Numbers | MINOR 1, 4, 8, 12, 20, 30 OILFLAM 15.1, 20.1, 30.1, 50.1, 80.1, 120.1, 170.1, 200.1, 300.1, 400.1, 500.1, 600.1, 700.1, 800.1, 1000.1, 1200.1, 1550.1, 1800.1 |

Approval

This application to renew Ecoflam Bruciatori S.p.A. oil burners manufactured by the burners Division of Ariston Thermo Group of Italy of the following types and model numbers:

MAIOR P10, P15, P25, P35, P45, P60, P80, P120, P150.1, P200.1, P300.1, P400.1, P500.1, P600.1, P800.1, P1000.1, P1200.1, P1500.1, P1800.1

MINOR 1, 4, 8, 12, 20, 30, and


OILFLAM 15.1, 20.1, 30.1, 50.1, 80.1, 120.1, 170.1, 200.1, 300.1, 400.1, 500.1, 600.1, 700.1, 800.1, 1000.1, 1200.1, 1550.1, 1800.1

is approved subject to any importer or supplier of these burners ensuring the following:

Conditions

1. Each purchaser of a Ecoflam Bruciatori S.p.A. MAIOR, MINOR or OILFLAM oil burner of the specified model numbers must be provided with a copy of the Ecoflam Bruciatori S.p.A. manufacturer's operating and maintenance instructions.
2. The register numbers as specified in Appendix 1 must be fixed to each Ecoflam Bruciatori S.p.A. MAIOR, MINOR or OILFLAM oil burner of the specified model numbers in a manner that will ensure it will remain legible for the life of the burner under the conditions in which the burner is installed and operated.
3. A plate stating that only diesel including low flash point diesel is to be used in the burner must be fixed to each Ecoflam Bruciatori S.p.A. MAIOR, MINOR or OILFLAM oil burner of the specified model numbers in a manner that will ensure it will remain legible for the life of the burner under the conditions in which the burner is installed and operated.
4. The importer or supplier of a listed Ecoflam Bruciatori S.p.A. MAIOR, MINOR or OILFLAM oil burner of the specified model numbers must advise the Manager Certifications, Approvals and Registrations Team, High Hazards and Specialist Services at WorkSafe New Zealand if the burner develops faults or fails in service due to product malfunction, defective manufacturer's workmanship or design failure that could render the equipment unsafe or lead to unsafe burner operating conditions.
5. This approval is invalidated for a Ecoflam Bruciatori S.p.A. MAIOR, MINOR or OILFLAM oil burner of the specified model numbers if there are any changes to the design of that model of Ecoflam Bruciatori S.p.A. oil burner.
6. The import or supply of Ecoflam Bruciatori S.p.A. MAIOR, MINOR or OILFLAM oil burner of the specified model numbers remains valid until 6 July 2020.

Taking into account the factors listed above, I am satisfied that the application meets the prescribed requirements.



George Hewitt

Date:

29th July 2015

Principal Advisor

Hazardous Substances

Disclaimer

This approval relates solely to a burner in accordance with Clause 68 of Schedule 8 of the Hazardous Substances (Dangerous Goods and Scheduled Toxic Substances) Transfer Notice 2004.

This approval does not obviate the need for the person in charge to ensure compliance with other relevant aspects of HSNO legislation and related regulations, or other legislation including, but not limited to, the Resource Management Act, the Building Act, Health and Safety in Employment Act, and any local authority requirements.

Appendix 1

| BUR register number | Type | Models |
|---------------------|---------|---|
| BUR1001A | MAIOR | P10, P15, P25, P35, P45, P60, P80, P120, P150.1, P200.1, P300.1, P400.1, P500.1, P600.1, P800.1, P1000.1, P1200.1, P1500.1, P1800.1 |
| BUR1001B | MINOR | 1, 4, 8, 12, 20, 30 |
| BUR1001C | OILFLAM | 15.1, 20.1, 30.1, 50.1, 80.1, 120.1, 170.1, 200.1, 300.1, 400.1, 500.1, 600.1, 700.1, 800.1, 1000.1, 1200.1, 1550.1, 1800.1 |